



HYDROGEOLOGIC DATABASE Chemical Analysis

[Click HERE to View Information for Well HT4](#)

Owner Name: **Brentbur Water Association / Mike Brazeal**

Well Key: **HT4**

Site Type: **Well**

TRS: **30N/03E-24M**

Sample Results Color Code Legend

Sample Exceeds [None
Secondary
Primary] **MCL**



		Bicarbonate				Conductivity		Hardness			Turbidity						
Source	Date	Alk	As		Ca	Cl		Fe		K	Mg	Mn	Na	NO3	SO4		TDS
WAV	2/19/2019		0.005			12.1	266	2.88	118.7			0.075	13.6	< 0.10	7.8	30	161
WAV	4/10/2019							0.14				0.005					

Select Summary Statistics

Avg As:	0.005	Avg Cl:	12.1	Avg Hardness:	118.7	Avg NO3:	0.05
Median As:	0.005	Median Cl:	12.1	Median Hardness:	118.7	Median NO3:	0.05
Max As:	0.005	Max Cl:	12.1	Max Hardness:	118.7	Max NO3:	0.05

[Bacteria Samples \(distribution\):](#) No samples available

Disclaimer: Data presented has been collected from a variety of sources. Island County makes no guarantee as to the validity or accuracy of this data.
Please report any errors to the Island County Hydrogeologist.

Generated by the Island County Hydrogeologic Database

2 records printed on 9/17/2019

Note: Items with [blue frames and blue text](#) are clickable hyperlinks to additional information / resources.

Parameter labels with a [red fill color](#) are exhibiting an increasing trend, and those with a [green fill color](#) are exhibiting a decreasing trend.